


**Part Number.....7215-20AR**

Made in the USA..... Yes  
 Mounting..... Vertical  
 AC Rating Volts..... 125  
 AC Rating Amps..... 20  
 AC Rating Watts..... 2400  
 AC Rating Frequency-Hz..... 50/60 HZ  
 Circuit Breaker..... 20A  
 Pilot Light..... Green  
 On/Off Switch..... None  
 Over Current Protection..... CB  
 Power Cable AWG..... 12/3 SJT  
 Power Cable Length..... 15'  
 Plug Type..... NEMA 5-20P  
 Receptacle Type..... NEMA 5-20R  
 Receptacle Style..... Single  
 Receptacle Quantity..... 16  
 Max. Output per Powerstrip..... 20 Amp  
 Joule Rating..... N/A  
 UL Rating..... 60950-1  
 Clamping Level..... N/A  
 Response Time..... N/A  
 Max. Surge Current..... N/A  
 EMI/RFI Noise Reduction..... N/A  
 Surge Indicator Red LED..... N/A  
 Connected Equipment Warranty..... N/A  
 Product Warranty-GLCC..... 1 year  
 Certification/Agency Approvals..... UL Approved  
 Unit Weight lbs..... 6

Rev.	Date	Dr.	CKD/APPV.D.	Description
A	02/04/02	TK	-	CHANGED INDICOTER LIGHT TO PILOT PIHT



NOTE: UL APPROVED

TOLERANCES UNLESS OTHERWISE SPECIFIED DECIMALS 0.0 = ± 0.100 0.00 = ± 0.020 0.000 = ± 0.005 ANGLES = ± 1°	Dr.	T.C.K.	Dr.	11/09/00	Title <b>721520AR</b> GREAT LAKES
	DES		Dr.		
	APVA		Dr.		
	SCALE	N/A	SHT	1 of 1	
Great Lakes <small>POWER &amp; CONTROL CO., INC.</small>					DWG No. 721520AR.dwg Rev. -