

What are the signal strength requirements for the Alarm.com Fire Communicator (ADC-FC100)?

A minimum sustained signal strength of 2 bars is required for optimal performance when using the Alarm.com Fire Communicator (ADC-FC100).

For information about finding the signal strength, see [Remotely find the signal strength of a module](#).