

## What monitoring station settings need to be set in order to use the Alarm.com Fire Communicator (ADC-FC100)?

Unlike other Alarm.com products (e.g., SDS Gunshot Sensors), no additional settings need to be enabled for monitoring stations to support the Alarm.com Fire Communicator (ADC-FC100). However, it is essential that the panel, FC100, and Partner Portal or MobileTech app are synchronized with the correct central monitoring station forwarding method: either Contact ID (CID) or Security Industry Association (SIA).