

What UL Standards and other certifications does the Alarm.com Fire Communicator (ADC-FC100) meet?

Panel manufacturers have their panels tested by Nationally Recognized Testing Laboratories (NRTL) in order to meet certain industry standards. Manufacturers have tested their panels to meet the following standards and certifications when using an Alarm.com Fire Communicator (ADC-FC100), so long as the appropriate adjustments for standard and certification conformity are set.

- ETL Tested
 - UL 864 - Standard for Control Units and Accessories for Fire Alarm Systems
 - To view the certification, see [UL Mark Certification of Compliance](#).
- NFPA 72 Compliant
- CSFM Listed
 - To view the certification, see [ADC-FC100-T10 - ADC Cert - US CSFM](#).
- LAFD Listed
 - To view the certification, see [ADC-FC100-T10 - ADC Cert - US LAFD](#).
- NYC Fire Dept. Certificate of Approval
 - To view the certification, see [ADC-FC100-T10 - ADC Cert - US FDNY](#).

Note: The Alarm.com Fire Communicator (ADC-FC100) is always in UL mode. Unlike other panels, no additional steps are required for the module to meet UL standards.